


- 43.23 A room with a sensible cooling load of 10 tons and a latent load of $5\frac{\text{gal}}{\text{hr}}$ is maintained at 74°F and 50% RH by an air column with bypass as shown. After bypass air is mixed with fully saturated discharge air from the coil, the mixed air is supplied to the room at 63°F . What percentage of the total supply air volume bypasses the coil?



- A. 37%
- B. 43%
- C. 57%
- D. 63%

Determine the sensible load in $\frac{\text{Btu}}{\text{hr}}$:

$$\dot{Q}_s = (10\text{ tons}) \left(12,000 \frac{\text{Btu}}{\text{hr ton}} \right) = 120,000 \frac{\text{Btu}}{\text{hr}}$$

Determine the latent load in $\frac{\text{Btu}}{\text{hr}}$. Look up the latent vaporization of steam, h_{fg} , at the room (return) temperature, $T = 74^\circ\text{F}$ using the steam table, [Properties of Saturated Water](#). If pressed for time, assume $h_{fg} \approx 1000 \frac{\text{Btu}}{\text{lb}}$.

$$\dot{Q}_L = \dot{m}\Delta h = \rho\dot{V}h_{fg}$$

$$\dot{Q}_L = \left(5\frac{\text{gal}}{\text{hr}}\right) \left(\frac{1\text{ft}^3}{7.48\text{gal}}\right) \left(\frac{62.4\text{lb}}{1\text{ft}^3}\right) \left(1051\frac{\text{Btu}}{\text{lb}}\right) = 43,839\frac{\text{Btu}}{\text{hr}}$$

Calculate the **Sensible Heat Ratio**:

$$SHR = \frac{\dot{Q}_s}{\dot{Q}_t} = \frac{\dot{Q}_s}{\dot{Q}_s + \dot{Q}_L} = \frac{120,000\frac{\text{Btu}}{\text{hr}}}{120,000\frac{\text{Btu}}{\text{hr}} + 43,839\frac{\text{Btu}}{\text{hr}}} = 0.73$$

Use the protractor on the top left corner of the **Psychrometric Chart** to draw a line with the slope $SHR = 0.73$ and draw a parallel line on the actual psych chart passing through the room condition, $T = 74^\circ F$, $\phi = 50\%$. The intersection of this process line with the saturation curve is the physical temperature of the coil, i.e. **apparatus dew point** (ADP).

$$T_{ADP} = 44^\circ F$$

Calculate the coil efficiency and bypass factor for the air column. The bypass factor represents the percentage of supply air volume bypassing the coil.

$$\eta_{coil} = \frac{T_{return} - T_{supply}}{T_{return} - T_{ADP}} = \frac{74^\circ F - 63^\circ F}{74^\circ F - 44^\circ F} = .37$$

$$BF = 1 - \eta_{coil} = 1 - .37 = .63 = 63\%$$

Note the large amount of bypass is an intentional aspect of the design for dehumidification purposes and not a reflection of poor performance in this application.

Answer D