

**34.20** (8) 15,000cfm computer room air conditioning units are provided to cool a data center in a “N+2” redundant configuration such that (6) units are normally running and (2) units are normally in standby. Each unit has a 7.5bhp fan with variable speed control which delivers its full design volume at 60Hz. The data center operates 24/7 and the average cost of electricity is \$0.16/kWh. What is the annual savings associated with running all units at a reduced speed providing the same total volume of air? Assume all fan motors have an efficiency of 90%.

- A. \$10,600
- B. \$13,100
- C. \$18,500
- D. \$22,900

In the initial configuration, Scenario 1, (6) units are running at 100% speed to produce their maximum airflow and (2) units are on standby i.e. not running. Calculate the total volume flow rate of air required to satisfy the room.

$$Q_{total} = 6Q_1$$

$$Q_{total} = (15,000cfm) = 90,000cfm$$

In Scenario 2 when all units are run, the volume required from each unit is reduced. Calculate the required cfm per unit.

$$Q_2 = \frac{Q_{total}}{8} = \frac{90,000cfm}{8} = 11,250cfm$$

Use the **Fan Laws** (1b) to determine the power per unit for Scenario 2. (For clarity, this solution uses bhp rather than  $W$ , as the motor efficiency will be used later to find the electrical power input,  $\dot{W}_{in}$ . There is no change in diameter or density. Fan speed,  $rpm$ , is linearly proportional to volume flow rate,  $Q$ .)

$$\frac{bhp_2}{bhp_1} = \left(\frac{N_2}{N_1}\right)^3 = \left(\frac{Q_2}{Q_1}\right)^3$$

$$bhp_2 = bhp_1 \left(\frac{Q_2}{Q_1}\right)^3 = (7.5bhp) \left(\frac{11,250cfm}{15,000cfm}\right)^3 = 3.16bhp \text{ (per unit)}$$

Find the total bhp for both scenarios. Note Scenario 1 uses only (6) units and Scenario 2 uses all (8) units.

$$bhp_{2,total} = (8) (3.16bhp) = 25.31hp$$

$$bhp_{1,total} = (6) (7.5bhp) = 45hp$$

Calculate the total reduction in *bhp*.

$$bhp_{1,total} - bhp_{2,total} = 45hp - 25.31hp = 19.69hp$$

Apply the motor efficiency to determine the input electrical power and convert units to *KW*.

$$\dot{W}_{in} = \frac{bhp}{\eta_{motor}} = \left( \frac{19.69hp}{0.9} \right) \left( \frac{0.7457KW}{hp} \right) = 16.31KW$$

Determine the annual savings for this reduction in demand.

$$Savings = (16.31KW) \left( \frac{24hr}{day} \right) (365days) \left( \frac{\$0.16}{kWh} \right) = \$22,863$$

**Answer D**