

33.6 A hotel with 400 units requires a maximum cold water supply of 5gpm per unit with a diversity factor of 60%. The supply line is 5,000 feet long and made of 8 inch standard weight steel with a roughness coefficient of $C = 130$. The minimum required pressure for all fixtures in the hotel is 80psig. The start of the supply line is 100 feet above the delivery end at the hotel. What is the minimum pressure required at the start of the line?

- A. 93psig
- B. 108psig
- C. 128psig
- D. 180psig

Start by writing the **Bernoulli Equation**.

$$\frac{P_1}{\gamma} + \frac{v_1^2}{2g} + z_1 = \frac{P_2}{\gamma} + \frac{v_2^2}{2g} + z_2 + h_f$$

Neglect velocity and isolate the unknown P_1 .

$$\frac{P_1}{\gamma} = \frac{P_2}{\gamma} + (z_2 - z_1) + h_f$$

The design volume flow rate, Q , depends on the required volume per unit, the number of units, and the diversity.

$$Q = (400 \text{ units}) \left(5 \frac{\text{gpm}}{\text{unit}} \right) (0.6) = 1200 \text{gpm}$$

Using the **Steel Pipe Friction Tables** look up the friction loss for 1200gpm through a nominal 8 inch pipe.

$$h_{d \text{ loss}} = 4.2 \text{ft per } 100 \text{ft}$$

The tables assume a **Roughness Factor** of $C = 100$, but this problem has given a roughness factor of $C = 130$, which implies there is less friction loss. A table of **Surface Roughness Factors** is given immediately before the steel pipe friction tables and provides correction factors for various values of the surface roughness, C . Select the correction factor for $C = 130$ and find the actual losses.

$$h_f = \left(\frac{4.2 \text{ft}}{100 \text{ft}} \right) (5000 \text{ft}) (0.62) = 130.2 \text{ft}$$

Use the rule of thumb conversion factor for water $2.31 \frac{\text{ft}}{\text{psi}}$ for convenience converting between pressure units and feet of head. Note that $\Delta z = z_2 - z_1$ has a negative value since $z_1 > z_2$ due to the start of the supply line being higher than the delivery point. Solve for P_1 .

$$\frac{P_1}{\gamma} = \frac{P_2}{\gamma} + (z_2 - z_1) + h_f$$

$$\frac{P_1}{\gamma} = (80psi) \left(2.31 \frac{ft}{psi} \right) - 100ft + 130.2ft = 215ft$$

$$P_1 = \frac{215ft}{2.31 \frac{ft}{psi}} = 93psig$$

Since the required fixture pressure and answer choices are given in *psig*, it is not necessary to account for atmospheric pressure at any point in the problem.

Answer A